



# NC Fuel Gas

1<sup>st</sup> Qtr. 2014 Code Answers in brown (Jan-Mar) 2<sup>nd</sup> Qtr. 2014 Code Answers in green (Apr- Jun)  
3<sup>rd</sup> Quarter 2014 Code Answers in blue (Jul-Sep) 4<sup>th</sup> Quarter 2014 Code Answers in red (Oct-Dec)

## Table of Contents

Chapter 1 Administration	Chapter 2 Definitions
Chapter 3 General Regulations	Chapter 4 Gas Piping Install.
Chapter 5 Chimneys & Vents	Chapter 6 Specific Appliances.
Chapter 7 Gaseous Hydrogen S.	Chapter 8 Ind./Special Waste
POLICY	OTHER

### 100 Chapter 1 Administration

### 200 Chapter 2 Definitions

### 300 Chapter 3 General Regulations

**303.3 #5 - Question:** If a gas appliance is installed in the attic, behind a knee wall, is a closer required?

**Answer:** Yes, a closer is required. See email from Dan Dittman

From: Dittman, Daniel E [mailto:dan.dittman@ncdoi.gov]

Sent: Thursday, March 13, 2014 10:48 AM

To: Rowland, Tommy D.

Subject: RE: Fuel Gas 303.3 #5

Mr. Rowland,

If the knee wall is into a bonus room, well then that is not an appliance that is opening into a space used as a bedroom or bathroom.

If that bonus room is also a bedroom, then this section would apply, and yes, the closure would be required.



# NC Fuel Gas

1<sup>st</sup> Qtr. 2014 Code Answers in brown (Jan-Mar) 2<sup>nd</sup> Qtr. 2014 Code Answers in green (Apr- Jun)  
3<sup>rd</sup> Quarter 2014 Code Answers in blue (Jul-Sep) 4<sup>th</sup> Quarter 2014 Code Answers in red (Oct-Dec)

Does this answer your question?

Thanks,

Daniel Dittman, PE, CMVP

919-661-5880 x237

NC DOI

Chief Mechanical Code Consultant

## 400 Chapter 4 Gas Piping

**406.1.4 - Question:** House on Temp Heat, does the entire gas line need to be tested at the final, or just the section that is not under operation?

**Answer:** The gas line is permitted to be tested in sections per 406.1.4. All sections of the gas line must be tested and no section may be tied into the gas service without being tested.

406.1.4 Section testing. A piping system shall be permitted to be tested as a complete unit or in sections. Under no circumstances shall a valve in a line be used as a bulkhead between gas in one section of the piping system and test medium in an adjacent section, unless two valves are installed in series with a valved “telltale” located between these valves. A valve shall not be subjected to the test pressure unless it can be determined that the valve, including the valve-closing mechanism, is designed to safely withstand the test pressure.

## 500 Chapter 5 Chimneys & Vents

## 600 Chapter 6 Specific Appliances



# NC Fuel Gas

1<sup>st</sup> Qtr. 2014 Code Answers in brown (Jan-Mar) 2<sup>nd</sup> Qtr. 2014 Code Answers in green (Apr- Jun)  
3<sup>rd</sup> Quarter 2014 Code Answers in blue (Jul-Sep) 4<sup>th</sup> Quarter 2014 Code Answers in red (Oct-Dec)

**623.7 - Question:** A contractor wants to paint a wood shelf with fire retardant paint and install it less than 30 inches above a gas cooktop. Would this be allowed?

**Answer:** No. Section 623.7 states the 30 inch clearance is required to combustibles. Painting wood with a fire retardant paint does not make it non-combustible.

623.7 (IFGS) Vertical clearance above cooking top. Household cooking appliances shall have a vertical clearance above the cooking top of not less than 30 inches (760 mm) to combustible material and metal cabinets. A minimum clearance of 24 inches (610 mm) is permitted where one of the following is installed:

1. The underside of the combustible material or metal cabinet above the cooking top is protected with not less than 1/4-inch (6 mm) insulating millboard covered with sheet metal not less than 0.0122 inch (0.3 mm) thick.
2. A metal ventilating hood constructed of sheet metal not less than 0.0122 inch (0.3 mm) thick is installed above the cooking top with a clearance of not less than 1/4 inch (6.4 mm) between the hood and the underside of the combustible material or metal cabinet. The hood shall have a width not less than the width of the appliance and shall be centered over the appliance.
3. A listed cooking appliance or microwave oven is installed over a listed cooking appliance and in compliance with the terms of the manufacturer's installation instructions for the upper appliance.

## 700 Chapter 7 Gaseous Hydrogen Systems

### Policy

**Policy - Question:** Can you use a storm collar to dress up a vent that passes through the sheetrock ceiling?



## NC Fuel Gas

1<sup>st</sup> Qtr. 2014 Code Answers in brown (Jan-Mar) 2<sup>nd</sup> Qtr. 2014 Code Answers in green (Apr- Jun)  
3<sup>rd</sup> Quarter 2014 Code Answers in blue (Jul-Sep) 4<sup>th</sup> Quarter 2014 Code Answers in red (Oct-Dec)

**Answer:** Yes, this has been a common practice to invert a storm collar and use it as a beauty ring to hide the sheetrock being cut back from the vent.

Another common practice is to cut the sheetrock back to the required clearance and fill the space in with mud. The mud is considered non-combustible.

**Policy - Question:** If a house or condo has a gas stub and 220 electrical range receptacle and the range is not installed and this is the only gas stub in the house, what is the proper procedure for finaling out this inspection?

**Answer:** Document what is there when the final is completed. If there is no range, make sure the gas outlet is capped off.

From: Spidel, Bill

Sent: Wednesday, March 12, 2014 10:17 AM

To: Rowland, Tommy D.

Cc: Jeff King

Subject: PNG policy on setting meters

Tommy, I spoke with Jeff King from PNG this am; He says their techs verify that an active appliance is set when they go out to do a meter install. If none installed, they will not set a meter.

By the same token, I have spoke this AM with Larry Currin with PSNC; he says they just set and clock the meter regardless of what the inspector notes are. Then, if there is an issue of no fuel consumption after the first month, they send a tech out to investigate. He says usually when the owner gets their first facilities charge on their monthly bill, and not using any, they call and have it removed...thanks

PS- both recommended the Inspectors make good clear notes on their inspections as to what if any appliances are actually there.

### **Other**



# NC Fuel Gas

1<sup>st</sup> Qtr. 2014 Code Answers in brown (Jan-Mar) 2<sup>nd</sup> Qtr. 2014 Code Answers in green (Apr- Jun)  
3<sup>rd</sup> Quarter 2014 Code Answers in blue (Jul-Sep) 4<sup>th</sup> Quarter 2014 Code Answers in red (Oct-Dec)

**Manufacture Instructions - Question:** Can the Maxitrol 325-3L regulator be used with a tankless water heater?

**Answer:** The 325-3L regulator has an individual maximum load of 140,000 Btu. If the maximum rating on the tankless water heater does not exceed a 140,000 Btu, then the answer is yes. Most tankless water heaters are rated at 199,000 Btu and would require the 325-5L regulator, which is rated at 425,000 Btu for an individual appliance. Keep in mind that some tankless water heaters have a range for the demand (ex. 90,000 to 199,000 Btus). The water heater will fire at the highest rate and adjust down.

See Reference sheet for Maxitrol Regulators at the end of this agenda